

Conculling

RECEIVED
JAN 4 1977

GOLDEN VALLEY ELECTRIC ASSOCIATION, INC.

State of Alaska
Public Utilities Commission

RULES AND REGULATIONS

8. SERVICE CONNECTIONS

8.1 General Requirements

As a guide for the applicant or his electrical engineer and contractor regarding an installation, the Association has prepared "Electric Service Requirements", copies of which are on file at all offices. As issued and as modified from time to time without notice, these specifications will be enforced.

The Association will furnish the meter and connect its distribution lines with the member's service equipment. The conduit, wiring, service equipment, enclosure, meter base, disconnect switch, and associated equipment shall be furnished by the member.

8.2 Location

The location of the member's service equipment and point of service connection will be determined by the Association. Alternate service locations preferred by member must be approved in writing by the Association.

8.3 Accessibility of Meter

The Association requires a member to install his service equipment on the building exterior so that all meters are accessible to Association employees from the outside of the member's building. Written exceptions to this rule may be granted by the Association where conditions warrant.

8.4 Primary Service

Where primary voltage service is supplied, the member at his expense and in a manner satisfactory to the Association, shall furnish, install and maintain on his premises such switches, transformers, regulators, relays, capacitors, and other equipment as the Association may deem necessary. The Association will determine whether primary or secondary voltage metering will be installed based on member's load.

Pursuant To
U-76-35 Order No. 7

Tariff Advice No. 22

Effective: JAN 1 1977

Issued by: Golden Valley Electric Association, Inc.

By: [Signature] Title: General Manager

Cancelling

Sheet No.

RECEIVED

JAN 4 1977

GOLDEN VALLEY ELECTRIC ASSOCIATION, INC.

State of Alaska
Public Utilities Commission

RULES AND REGULATIONS

8. SERVICE CONNECTIONS (Continued)

8.5 Underground Service

A member may obtain an underground service connection with the Association's underground distribution system by installing and maintaining the underground service connection at his own expense.

8.6 Service to Multi-Occupant Building

The member must arrange the wiring of a multi-occupant building so that the wiring for all stores or apartments will terminate at a common point or points designated by the Association.

8.7 Service to Mobile Home Courts

In order for the occupants of mobile home courts to receive service, the mobile home court owner must furnish, install, and maintain an overhead or underground secondary voltage distribution system in accordance with applicable electric codes and the Association's requirements.

8.8 Change in Location

Any change in the location of a service connection, provided such change is approved by the Association, will be made in accordance with Rule 10.

Pursuant To
U-76-35 Order No. 7


Tariff Advice No. 22

Effective:

JAN 1 1977

Issued by: Golden Valley Electric Association, Inc.

By:



Title:

General Manager